

**HFSARCHITECTS**

329 S. Rio Grande  
Salt Lake City, Utah 84101  
801-596-0691 • Fax: 596-0693 • [www.hfsa.com](http://www.hfsa.com)

---

**Addendum No. 03**

Project:	Provo DWS - HVAC System Upgrade & Ceiling Replacement	Date:	22 February 2005
Address:	1525 North Freedom Boulevard	Project No.:	0426.01
City, State:	Provo, Utah	Owner No.:	04210920
Owner:	DFCM	Agency:	Department of Workforce Services

---

**To all Bidders of Record:**

This addendum forms a part of the contract documents and modifies the original specifications and drawings as noted below. Items of general information are included without reference to the plans and specifications. Revisions to the specifications are referenced by page number and paragraph heading on that page. Revisions to the drawings are reference by the drawing number. Unless otherwise stated, any changes herein offset only the specific drawings, words, or paragraphs mentioned, and the balance of the drawings and specifications remain in full force. Acknowledge receipt of this addendum in the space provided on the Bid form. Failure to do so will subject the Bidder to disqualification.

Item No.	Section or Sheet No.	Description
----------	----------------------	-------------

---

**GENERAL ITEMS**

- 1-1 Additional Scope      The existing heads are pendant type with an escutcheon that makes it impossible to install in ceiling panels in one piece. It has been determined that the existing fire sprinklers, escutcheon, and piping drop shall be removed and replaced by semi-recessed fire sprinkler heads.

**Fire Sprinkler Head Demolition:**

The pendant type fire sprinklers mounted at the ceiling of both the lower and main level shall be removed and disposed of. The piping drop to these sprinklers shall also be removed, but may be modified and re-used for installation of the new sprinkler heads.

**Fire Sprinkler Head Installation:**

New fire sprinkler heads shall be installed throughout the lower level and the main level. These sprinkler heads shall be light hazard, quick response, semi-recessed pendant type heads with bright white escutcheons for all office areas. Ordinary hazard heads shall be used in electrical and storage rooms. A new piping drop shall be necessary to accommodate the ceiling elevation (modification of existing drops is also acceptable). For bidding purposes, allowance shall be made for one head in every 144 square feet of ceiling. Allowance shall also be made for re-routing of heads due to locations of new walls (see architectural plans). It shall not be necessary to center the new heads in the ceiling tiles; however, heads shall be placed in straight lines with the ceiling grid.

Item No.	Section or Sheet No.	Description
		<b>Shop Drawings:</b> Shop drawings shall be submitted to the architect for review. Drawings shall show demolition of existing heads and location of new heads. Sprinkler head types shall also be shown.
<b>SPECIFICATION ITEMS</b>		
1-2		None this addendum.
<b>DRAWING ITEMS</b>		
1-3	AE601	<b>DOOR SCHEDULE:</b> Add Door Number 113, provide door and frame the same as Door Number 105 shown in the schedule, provide hardware from group 01.
<b>PRIOR APPROVALS</b>		
1-4		None this addendum.
<b>ATTACHMENTS</b>		
1-5		